

**Citation and Compliance / Order No. 02\_57\_25J\_009**  
**IMPORTANT INFORMATION**

**Monitoring requirements not met for Henry Miller Library WS** as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor our water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our water meets health standards. During June and August 2024, we did not conduct the routine distribution and raw source water sampling for total coliform and cannot be sure of the quality of our drinking water during that time.

During October 2024, we did not collect the required number of repeat samples for total coliform in accordance with the approved bacteriological sampling site plan within 24 hours of notification of the total coliform positive sample result and therefore, cannot be sure of the quality of our drinking water during that time.

**What should I do?**

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required Sampling Frequency	Number of Samples	When All Samples Should Have Been Taken	When Samples Were or Will Be Taken
<i>Coliform Bacteria</i>	1 routine distribution coliform sample / month & 1 source coliform sample / month	0	June & August 2024	July & September 2024
<i>Coliform Bacteria</i>	3 distribution coliform repeat samples within 24 hours of notification of a routine total coliform detection	0	October 17, 2024	1 distribution repeat sample- October 18,2024 n1 distribution repeat sample - October 21,2024

**What is being done?**

We continue to have posted 'NOT POTABLE' at all water spigots and faucets. We also have a chlorine injector putting chlorine into our water. Chlorine levels are checked daily and reported to the County Health Department. We have posted this notice at the Henry Miller Library front gate and at the main library entrance as well as on our website.

For more information, please contact Magnus Toren 831-238-2890 or at [magnus@henrymiller.org](mailto:magnus@henrymiller.org)

This notice is posted by the Henry Miller Library WS State Water System ID# 2702805